



Document 2026/101/9326 - GENERAL (modified version of 2026/9321/101) - File No. 2026/101/3101
Approved by Registrar on 26/04/2026 22:49:57

http://www.kufos.ac.in/
LyQOB-QsD-ocFH-QAnrN



KUFOS HQRS, Panangad, Ernakulam



KERALA UNIVERSITY OF FISHERIES & OCEAN STUDIES
കേരള ഫിഷറീസ്-സമുദ്രപഠന സർവ്വകലാശാല

PANANGAD P.O., KOCHI 682 506, KERALA, INDIA
Phone:0484- 2703782, 2700598; Fax: 91-484-2700337; e-mail: utypanangad@kufos.ac.in



No.GA7/3101/2026

Panangad, Dated .

04.2026

QUOTATION NOTICE

Competitive quotations are invited for the “Supply and Installation of 1.5 ton inverter Air Conditioner for algal culture Facility at Hatchery FS Puduveyyu” with requirements/specifications as attached herewith:

Last date & time for receipt of quotation	05.05.2026	03.00pm
Date & time of opening of quotation	05.05.2026	03.30pm

The envelope containing the quotation should bear the superscription “Supply and Installation of 1.5 ton inverter Air Conditioner for algal culture Facility at Hatchery FS Puduveyyu, GA7/3101/2026” and should be sent to ‘The Registrar, Kerala University of Fisheries and Ocean Studies, Panangad, Kochi - 682506, Ernakulam District’.

More details will be available in the Office of Dr. Linoy Libini, Assistant Professor & Head Fisheries Station Puduveyyu, KUFOS on all working days with the permission of undersigned. Our GST Regn. No. is: 32AAAGK0031Q1ZL.

The rate quoted should be firm, inclusive of all taxes and any transportation cost to Fisheries Station, Puduveyyu. Period of firmness during which the rates would be firm is 30 days from the date of work orders.

All the terms and conditions applicable to University/Government quotation/Tenders are admissible to this also. Right to accept the quotation in full or in part or to reject without assigning any reason whatsoever is reserved with the undersigned.

REGISTRAR

To : Firms/ Programmer to publish on the website

Copy to: Dr. Linoy Libini, Assistant Professor & Head Fisheries Station Puduveyyu, KUFOS/UE/Spare



Technical Specification

Sl. NO	Specification	Requirement
1	Voltage	230V/50Hz/ single phase
2	Converter	5 in 1 Converter
3	Airflow volume	675 cfm
4	Antifreeze	Yes
5	Autorestart memory function	Yes
6	Condenser fins	Copper with Anti Corrosive blue fins
7	Cooling capacity	5000W/1.5 TR
8	Filter Configuration	Anti dust filter, Antiviral filter
9	Power	1650 Watts/7.6 Amps
10	Compressor warranty	10 years
11	Inverter board warranty	10 years

REGISTRAR

